

Attachment 2 - Apartment Design Guide compliance table

No.	Control	Comments	Compliance		
PART 3 – SETTING THE DEVELOPMENT					
3A	Site Analysis		Yes	No	N/A
3A-1	Site analysis illustrates that design decisions have been based on opportunities and constraints of the site conditions and their relationship to the surrounding context.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3B	Orientation		Yes	No	N/A
3B-1	Building types and layouts respond to the streetscape and site while optimising solar access within the development.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3B-2	Overshadowing of neighbouring properties is minimised during mid-winter.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3C	Public Domain Interface		Yes	No	N/A
3C-1	Transition between private and public domain is achieved without compromising safety and security.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3C-2	Amenity of the public domain is retained and enhanced.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3D	Communal and Public Open Space		Yes	No	N/A
3D-1	An adequate area of communal open space is provided to enhance residential amenity and to provide opportunities for landscaping.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p>Design Criteria Communal open space has a minimum area equal to 25% of the site.</p> <p>Required: 25% x 2,395m² = 598.75m²</p>	<p><u>Officer's Calculations:</u></p> <p>427.4m² (17.8%) COS along western boundary = boundary = 382.5m² COS at Bransgrove St front entry = 44.9m²</p> <p>Deficiency of 171.35m² Non-compliance considered acceptable in this instance – Refer to further discussion below.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	<p><u>Applicant's Calculations:</u></p> <p>As outlined in the Applicant's covering letter dated 8 November 2018 and GFA & COS Calculations Plan (Drawing No. SP-01, Issue A), the proposal is identified to provide two distinct COS area required as follows:</p> <ul style="list-style-type: none"> • Ground floor COS along western boundary = 383.3m²; and • 215.62m² of COS that is predominantly located in the landscaped front setback zone of Bransgrove St. <p>Based on the above, a total of 598.92m² (25%) of COS is provided, which demonstrates compliance with the minimum COS required.</p> <p><u>Officer's Calculations:</u></p> <p>The discrepancies in calculations result from exclusion of the following areas:</p> <ul style="list-style-type: none"> • Landscaped front setback zone of Bransgrove St forward of the courtyards of Units 1, 2 and the landscaped area forward of the nominated COS adjacent to the Bransgrove St entry; and • Planter boxes and walkway leading to the building entry adjacent to the courtyards of Units 1 and 10. <p>The landscaped area fronting Bransgrove St is excluded from calculations as it is considered to be perimeter landscaping and not useable COS.</p> <p>The planter boxes and walkway leading to the building entry adjacent to the courtyards of Units 1 and 10 are considered to be a circulation space and are excluded from COS calculations.</p>				

	<p>In this regard, based on the above, the total COS provided by the proposal is calculated to be a total of 427.4m², which represents 17.8% of the subject site, and a deficiency of 171.35m².</p> <p>The Design Guidance of Section 3D Communal and Public Open Space within the ADG outlines that <i>where developments are unable to achieve the design criteria, such as on small lots, sites within business zones or in a dense urban area, they should:</i></p> <ul style="list-style-type: none"> • Provide communal spaces elsewhere such as a landscaped roof top terrace or a common room, • Provide larger balconies or increased private open space for apartments • Demonstrate good proximity to public open space and facilities and/or provide contributions to public open space. <p>The subject site is identified as a dense urban area as defined by the ADG, however given the subject site is separated to Irwin Place Park by only one property, the provided COS by the proposal is supported in this instance. Although the proposal is deficient in the overall required COS, the COS which is provided on the ground floor accommodates for passive and active recreation for future residents and visitors. COS areas provided are easily accessible, include a playground, BBQ area, seating, weather protection and appropriately landscaped. Having regard to the facilities of the provided COS and resident's close access to public open space, the non-compliance to the minimum COS required is considered acceptable, in the context of the proposal and site, in this instance.</p>																
	Developments achieve a minimum of 50% direct sunlight to the principal usable part of the communal open space for a minimum of 2 hours between 9 am and 3 pm on 21 June (mid-winter).	The COS areas to the west and front (east) of the site would receive the min. 2 hours direct sunlight, mid-winter.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3D-2	Communal open space is designed to allow for a range of activities, respond to site conditions and be attractive and inviting.			<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>											
3D-3	Communal open space is designed to maximise safety.			<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>											
3D-4	Public open space, where provided, is responsive to the existing pattern and uses of the neighbourhood.			<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>											
3E	Deep Soil Zones			Yes	No	N/A											
3E-1	Deep soil zones provide areas on the site that allow for and support healthy plant and tree growth. They improve residential amenity and promote management of water and air quality.	Deep soil areas are provided to the rear (west) co-located with the COS area, which incorporates tree planting and landscaping.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
	<p>Design Criteria Deep soil zones are to meet the following minimum requirements:</p> <table border="1"> <thead> <tr> <th>Site area</th> <th>Minimum dimensions</th> <th>Deep soil zone (% of site area)</th> </tr> </thead> <tbody> <tr> <td>less than 650m²</td> <td>-</td> <td rowspan="4">7%</td> </tr> <tr> <td>650m² - 1,500m²</td> <td>3m</td> </tr> <tr> <td>greater than 1,500m²</td> <td>6m</td> </tr> <tr> <td>greater than 1,500m² with significant existing tree cover</td> <td>6m</td> </tr> </tbody> </table>	Site area	Minimum dimensions	Deep soil zone (% of site area)	less than 650m ²	-	7%	650m ² - 1,500m ²	3m	greater than 1,500m ²	6m	greater than 1,500m ² with significant existing tree cover	6m	<p>Required: 7% x 2,395m² = 167.65m²</p> <p>Provided: 258.7m² (167.5m² + 91.2m² rear), with min. 6m dimension.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Site area	Minimum dimensions	Deep soil zone (% of site area)															
less than 650m ²	-	7%															
650m ² - 1,500m ²	3m																
greater than 1,500m ²	6m																
greater than 1,500m ² with significant existing tree cover	6m																
3F	Visual Privacy			Yes	No	N/A											
3F-1	Adequate building separation distances are shared equitably between neighbouring sites, to achieve reasonable levels of external and internal visual privacy.			<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>											

Design Criteria

Separation between windows and balconies is provided to ensure visual privacy is achieved. Minimum required separation distances from buildings to the side and rear boundaries are as follows:

Building height	Habitable rooms and balconies	Non-habitable rooms
up to 12m (4 storeys)	6m	3m
up to 25m (5-8 storeys)	9m	4.5m
over 25m (9+ storeys)	12m	6m

Note:

Separation distances between buildings on the same site should combine required building separations depending on the type of room.

Gallery access circulation should be treated as habitable space when measuring privacy separation distances between neighbouring properties.

Building is 5 storeys in height

East: Bransgrove Street

South: Irwin Place

West:

Ground Floor – Min. 8.9m to edge of POS.

Levels 1-3 – Min. 10.22m to edge of balconies and living areas.

Level 4 (5th storey) – 10.22m to edge of balcony
Requires a min. 12m setback to the boundary measured from the outer face of the balcony.

Conditions imposed requiring a fixed 1.5m (measured from the FFL of the balcony) privacy screen to be installed along the western outer edge of the planter box to ensure that privacy is maintained between properties and residential amenity provided for future occupants.

North:

Ground Floor – Min. 6m to Units 8 & 9 bedrooms. Courtyards located within 6m separation area.

Levels 1-3 – Min. 6m to windows and outer face of balconies.

Level 4 (5th storey) –

The RFB approved at 1-3 Bransgrove St (DA2016/79) is 4 storeys in height, and as such Level 4 is adjacent to the roof of the future development on the neighbouring site.

The proposal provides a 9m setback to bedrooms of Units 46 & 47. Planter boxes are setback 8m, and encroach into the required 9m setback required to northern boundary. The planter boxes are considered acceptable in addressing potential overlooking of neighbouring



		sites, providing opportunities for planting for the balconies and adding visual interesting to the building when viewed from neighbouring sites.															
3F-2	Site and building design elements increase privacy without compromising access to light and air and balance outlook and views from habitable rooms and private open space.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3G	Pedestrian Access and Entries		Yes	No	N/A												
3G-1	Building entries and pedestrian access connects to and addresses the public domain.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3G-2	Access, entries and pathways are accessible and easy to identify.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3G-3	Large sites provide pedestrian links for access to streets and connection to destinations.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
3H	Vehicle Access		Yes	No	N/A												
3H-1	Vehicle access points are designed and located to achieve safety, minimise conflicts between pedestrians and vehicles and create high quality streetscapes.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3J	Bicycle and Car Parking		Yes	No	N/A												
3J-1	Car parking is provided based on proximity to public transport in metropolitan Sydney and centres in regional areas.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
	<p>Design Criteria For development in the following locations:</p> <ul style="list-style-type: none"> on sites that are within 800 metres of a railway station or light rail stop in the Sydney Metropolitan Area; or on land zoned, and sites within 400 metres of land zoned, B3 Commercial Core, B4 Mixed Use or equivalent in a nominated regional centre, <p>The minimum car parking requirement for residents and visitors is set out in the Guide to Traffic Generating Developments, or the car parking requirement prescribed by the relevant council, whichever is less.</p> <p>The car parking needs for a development must be provided off street.</p> <table border="1"> <thead> <tr> <th colspan="2">Control</th> </tr> </thead> <tbody> <tr> <td>1 bedroom spaces</td> <td>0.6</td> </tr> <tr> <td>2 bed</td> <td>0.9 spaces</td> </tr> <tr> <td>3 bed</td> <td>1.4 spaces</td> </tr> <tr> <td>4+ bed</td> <td>1.4 spaces</td> </tr> <tr> <td>Visitor</td> <td>0.2 spaces per dwelling</td> </tr> </tbody> </table>	Control		1 bedroom spaces	0.6	2 bed	0.9 spaces	3 bed	1.4 spaces	4+ bed	1.4 spaces	Visitor	0.2 spaces per dwelling	Refer to ARH SEPP and DCP compliance table.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Control																	
1 bedroom spaces	0.6																
2 bed	0.9 spaces																
3 bed	1.4 spaces																
4+ bed	1.4 spaces																
Visitor	0.2 spaces per dwelling																
3J-2	Parking and facilities are provided for other modes of transport.	Refer to ARH SEPP and DCP compliance table.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3J-3	Car park design and access is safe and secure		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3J-4	Visual and environmental impacts of underground car parking are minimised.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3J-5	Visual and environmental impacts of on-grade car parking are minimised.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												

3J-6	Visual and environmental impacts of above ground enclosed car parking are minimised.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
PART 4 – DESIGNING THE BUILDING					
4A	Solar and Daylight Access		Yes	No	N/A
4A-1	To optimise the number of apartments receiving sunlight to habitable rooms, primary windows and private open space.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Design Criteria	Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid-winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas. Required: 70% x 48 units = 33.6 (34) units minimum	39 out of 48 units (81.2%) achieve 3 hours (as per SEPP ARH)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
		A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid-winter. Maximum: 15% x 48 units = 7.2 (8) units maximum	4 out of 48 units (8.3%), being the single aspect south facing units, will not receive adequate sunlight mid-winter.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4A-2	Daylight access is maximised where sunlight is limited.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4A-3	Design incorporates shading and glare control, particularly for warmer months.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4B	Natural Ventilation		Yes	No	N/A
4B-1	All habitable rooms are naturally ventilated.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4B-2	The layout and design of single aspect apartments maximises natural ventilation.	Satisfactory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4B-3	The number of apartments with natural cross ventilation is maximised to create a comfortable indoor environment for residents.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Design Criteria	At least 60% of apartments are naturally cross ventilated in the first nine storeys of the building. Apartments at ten storeys or greater are deemed to be cross ventilated only if any enclosure of the balconies at these levels allows adequate natural ventilation and cannot be fully enclosed. Required: 60% x 48 = 28.8 (29) units	30 units (62.5%) are naturally cross ventilated.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
		Overall depth of a cross-over or cross-through apartment does not exceed 18m, measured glass line to glass line.	Single aspect units are less than 18m in depth.	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4C	Ceiling Heights		Yes	No	N/A
4C-1	Ceiling height achieves sufficient natural ventilation and daylight access.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Design Criteria	Measured from finished floor level to finished ceiling level, minimum ceiling heights are:	The proposed ceiling heights are as follows:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<ul style="list-style-type: none"> • Ground floor 2.7m • Level 1 2.7m 	<input type="checkbox"/>	<input type="checkbox"/>

	<table border="1"> <tr> <th colspan="2">Minimum ceiling height for apartment and mixed use buildings</th> </tr> <tr> <td>Habitable rooms</td> <td>2.7m</td> </tr> <tr> <td>Non-habitable</td> <td>2.4m</td> </tr> <tr> <td>For 2 storey apartments</td> <td>2.7m for main living area floor 2.4m for second floor, where its area does not exceed 50% of the apartment area</td> </tr> <tr> <td>Attic spaces</td> <td>1.8m at edge of room with a 30 degree minimum ceiling slope</td> </tr> <tr> <td>If located in mixed used areas</td> <td>3.3m for ground and first floor to promote future flexibility of use</td> </tr> </table> <p>These minimums do not preclude higher ceilings if desired.</p>	Minimum ceiling height for apartment and mixed use buildings		Habitable rooms	2.7m	Non-habitable	2.4m	For 2 storey apartments	2.7m for main living area floor 2.4m for second floor, where its area does not exceed 50% of the apartment area	Attic spaces	1.8m at edge of room with a 30 degree minimum ceiling slope	If located in mixed used areas	3.3m for ground and first floor to promote future flexibility of use	<ul style="list-style-type: none"> Level 2 2.7m Level 3 2.7m Level 4 2.7m 			
Minimum ceiling height for apartment and mixed use buildings																	
Habitable rooms	2.7m																
Non-habitable	2.4m																
For 2 storey apartments	2.7m for main living area floor 2.4m for second floor, where its area does not exceed 50% of the apartment area																
Attic spaces	1.8m at edge of room with a 30 degree minimum ceiling slope																
If located in mixed used areas	3.3m for ground and first floor to promote future flexibility of use																
4C-2	Ceiling height increases the sense of space in apartments and provides for well-proportioned rooms.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
4C-3	Ceiling heights contribute to the flexibility of building use over the life of the building.	The proposal is for a residential flat building and ceiling heights provided are acceptable.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
4D	Apartment Size and Layout		Yes	No	N/A												
4D-1	The layout of rooms within an apartment is functional, well organised and provides a high standard of amenity.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
	<p>Design Criteria</p> <p>Apartments are required to have the following minimum internal areas:</p> <table border="1"> <thead> <tr> <th>Apartment type</th> <th>Minimum internal area</th> </tr> </thead> <tbody> <tr> <td>Studio</td> <td>35m²</td> </tr> <tr> <td>1 bedroom</td> <td>50m²</td> </tr> <tr> <td>2 bedroom</td> <td>70m²</td> </tr> <tr> <td>3 bedroom</td> <td>90m²</td> </tr> </tbody> </table> <p>The minimum internal areas include only one bathroom. Additional bathrooms increase the minimum internal area by 5m² each.</p> <p>A fourth bedroom and further additional bedrooms increase the minimum internal area by 12m² each.</p>	Apartment type	Minimum internal area	Studio	35m ²	1 bedroom	50m ²	2 bedroom	70m ²	3 bedroom	90m ²	All units comply with the minimum internal areas.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Apartment type	Minimum internal area																
Studio	35m ²																
1 bedroom	50m ²																
2 bedroom	70m ²																
3 bedroom	90m ²																
	Every habitable room must have a window in an external wall with a total minimum glass area of not less than 10% of the floor area of the room. Daylight and air may not be borrowed from other rooms.	All habitable rooms have adequate access to daylight and ventilation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
4D-2	Environmental performance of the apartment is maximised.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
	<p>Design Criteria</p> <p>Habitable room depths are limited to a maximum of 2.5 x the ceiling height.</p>	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
	In open plan layouts (where the living, dining and kitchen are combined) the maximum habitable room depth is 8m from a window.	All units comply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												

4D-3	Apartment layouts are designed to accommodate a variety of household activities and needs.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	Design Criteria Master bedrooms have a minimum area of 10m ² and other bedrooms 9m ² (excluding wardrobe space).	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	Bedrooms have a minimum dimension of 3m (excluding wardrobe space).	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	Living rooms or combined living/dining rooms have a minimum width of: • 3.6m for studio and 1 bedroom apartments • 4m for 2 and 3 bedroom apartments.	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	The width of cross-over or cross-through apartments are at least 4m internally to avoid deep narrow apartment layouts.	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
4E	Private Open Space and Balconies		Yes	No	N/A															
4E-1	Apartments provide appropriately sized private open space and balconies to enhance residential amenity.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	Design Criteria All apartments are required to have primary balconies as follows: <table border="1" data-bbox="288 898 746 1122"> <thead> <tr> <th>Dwelling type</th> <th>Minimum area</th> <th>Minimum depth</th> </tr> </thead> <tbody> <tr> <td>Studio apartments</td> <td>4m²</td> <td>-</td> </tr> <tr> <td>1 bedroom apartments</td> <td>8m²</td> <td>2m</td> </tr> <tr> <td>2 bedroom apartments</td> <td>10m²</td> <td>2m</td> </tr> <tr> <td>3+ bedroom apartments</td> <td>12m²</td> <td>2.4m</td> </tr> </tbody> </table> The minimum balcony depth to be counted as contributing to the balcony area is 1m.	Dwelling type	Minimum area	Minimum depth	Studio apartments	4m ²	-	1 bedroom apartments	8m ²	2m	2 bedroom apartments	10m ²	2m	3+ bedroom apartments	12m ²	2.4m	Each unit is provided with the minimum POS areas and dimensions.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Dwelling type	Minimum area	Minimum depth																	
Studio apartments	4m ²	-																		
1 bedroom apartments	8m ²	2m																		
2 bedroom apartments	10m ²	2m																		
3+ bedroom apartments	12m ²	2.4m																		
For apartments at ground level or on a podium or similar structure, a private open space is provided instead of a balcony. It must have a minimum area of 15m ² and a minimum depth of 3m.	Each ground floor courtyard provided with a minimum POS area of 15m ² and minimum dimension of 3m.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																
4E-2	Primary private open space and balconies are appropriately located to enhance liveability for residents.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
4E-3	Private open space and balcony design is integrated into and contributes to the overall architectural form and detail of the building.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
4E-4	Private open space and balcony design maximises safety.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
4F	Common Circulation and Spaces		Yes	No	N/A															
4F-1	Common circulation spaces achieve good amenity and properly service the number of apartments.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	Design Criteria The maximum number of apartments off a circulation core on a single level is eight.	1 lift core servicing the building, and each level as follows: • Ground floor = 10 units • Levels 1-3 = 10 units • Level 4 = 8 units The Design Guidance outlines that <i>where criteria 1 is not achieved, no more than 12 apartments should be provided off a circulation core on a level.</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>															

		The lift core services a maximum of 10 units for the ground level to Level 3, and is considered acceptable.													
	For buildings of 10 storeys and over, the maximum number of apartments sharing a single lift is 40.	Not applicable.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>										
4F-2	Common circulation spaces promote safety and provide for social interaction between residents.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4G	Storage		Yes	No	N/A										
4G-1	Adequate, well designed storage is provided in each apartment.														
	<p>Design Criteria In addition to storage in kitchens, bathrooms and bedrooms, the following storage is provided:</p> <table border="1"> <thead> <tr> <th>Dwelling type</th> <th>Storage size volume</th> </tr> </thead> <tbody> <tr> <td>Studio apartments</td> <td>4m³</td> </tr> <tr> <td>1 bedroom apartments</td> <td>6m³</td> </tr> <tr> <td>2 bedroom apartments</td> <td>8m³</td> </tr> <tr> <td>3+ bedroom apartments</td> <td>10m³</td> </tr> </tbody> </table> <p>At least 50% of the required storage is to be located within the apartment.</p>	Dwelling type	Storage size volume	Studio apartments	4m ³	1 bedroom apartments	6m ³	2 bedroom apartments	8m ³	3+ bedroom apartments	10m ³	<p>Most units have sufficient internal storage.</p> <p>Additional storage is provided to units within the basement.</p> <p>Conditions are imposed within the original consent requiring compliance with the ADG minimum requirements.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Dwelling type	Storage size volume														
Studio apartments	4m ³														
1 bedroom apartments	6m ³														
2 bedroom apartments	8m ³														
3+ bedroom apartments	10m ³														
4G-2	Additional storage is conveniently located, accessible and nominated for individual apartments.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4H	Acoustic Privacy		Yes	No	N/A										
4H-1	Noise transfer is minimised through the siting of buildings and building layout.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4H-2	Noise impacts are mitigated within apartments through layout and acoustic treatments.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4J	Noise and Pollution		Yes	No	N/A										
4J-1	In noisy or hostile environments the impacts of external noise and pollution are minimised through the careful siting and layout of buildings.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4J-2	Appropriate noise shielding or attenuation techniques for the building design, construction and choice of materials are used to mitigate noise transmission.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4K	Apartment Mix		Yes	No	N/A										
4K-1	A range of apartment types and sizes is provided to cater for different household types now and into the future.	Proposal is for 7 x 1-bedroom (15%), 36 x 2-bedroom (75%) and 5 x 3-bedroom (10%) units.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4K-2	The apartment mix is distributed to suitable locations within the building.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4L	Ground Floor Apartments		Yes	No	N/A										
4L-1	Street frontage activity is maximised where ground floor apartments are located.	Pedestrian access is provided to ground floor units and	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4L-2	Design of ground floor apartments delivers amenity and safety for residents.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4M	Façades		Yes	No	N/A										
4M-1	Building facades provide visual interest along the street while respecting the character of the local area.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4M-2	Building functions are expressed by the façade.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4N	Roof Design		Yes	No	N/A										
4N-1	Roof treatments are integrated into the building design and positively respond to the street.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4N-2	Opportunities to use roof space for residential accommodation and open space are maximised.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										

4N-3	Roof design incorporates sustainability features.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4O	Landscape Design	Yes	No	N/A
4O-1	Landscape design is viable and sustainable.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4O-2	Landscape design contributes to the streetscape and amenity.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4P	Planting on Structures	Yes	No	N/A
4P-1	Appropriate soil profiles are provided.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4P-2	Plant growth is optimised with appropriate selection and maintenance.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4P-3	Planting on structures contributes to the quality and amenity of communal and public open spaces.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4Q	Universal Design	Yes	No	N/A
4Q-1	Universal design features are included in apartment design to promote flexible housing for all community members.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<i>Developments achieve a benchmark of 20% of the total apartments incorporating the Liveable Housing Guideline's silver level universal design features</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Conditions imposed for 20% of total apartments to achieve the Liveable Housing Guideline's silver level universal design			
4Q-2	A variety of apartments with adaptable designs are provided.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4Q-3	Apartment layouts are flexible and accommodate a range of lifestyle needs.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4R	Adaptive Reuse	Yes	No	N/A
4R-1	New additions to existing buildings are contemporary and complementary and enhance an area's identity and sense of place.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4R-2	Adapted buildings provide residential amenity while not precluding future adaptive reuse.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4S	Mixed Use	Yes	No	N/A
4S-1	Mixed use developments are provided in appropriate locations and provide active street frontages that encourage pedestrian movement.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4S-2	Residential levels of the building are integrated within the development, and safety and amenity is maximised for residents.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4T	Awnings and Signage	Yes	No	N/A
4T-1	Awnings are well located and complement and integrate with the building design.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4T-2	Signage responds to the context and desired streetscape character.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4U	Energy Efficiency	Yes	No	N/A
4U-1	Development incorporates passive environmental design.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4U-2	Development incorporates passive solar design to optimise heat storage in winter and reduce heat transfer in summer.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4U-3	Adequate natural ventilation minimises the need for mechanical ventilation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4V	Water Management and Conservation	Yes	No	N/A
4V-1	Potable water use is minimised.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4V-2	Urban stormwater is treated on site before being discharged to receiving waters.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4V-3	Flood management systems are integrated into site design.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4W	Waste Management	Yes	No	N/A
4W-1	Waste storage facilities are designed to minimise impacts on the streetscape, building entry and amenity of residents.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4W-2	Domestic waste is minimised by providing safe and convenient source separation and recycling.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4X	Building Maintenance	Yes	No	N/A
4X-1	Building design detail provides protection from weathering.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4X-2	Systems and access enable ease of maintenance.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4X-3	Material selection reduces ongoing maintenance costs.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>